



A-94-16

II-D-91



INDIANAPOLIS POWER & LIGHT COMPANY

June 14, 1994



Ms. Genevieve Nearmyer
U.S. EPA Region V
Air and Radiation Division (AE-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604

REGULATION DEVELOPMENT BRANCH
U.S. EPA REGION V

RE: Procedure for Replacing Missing
Fuel Flow Values for E.W. Stout GT-4

Dear Ms. Nearmyer:

Indianapolis Power and Light Company (IPL) will be using Appendix D to report Sulfur Dioxide emissions from E.W. Stout's GT-4. Part 75 Appendix D 2.3.2 states, "If no oil flow rate data are available at a load recorded during the missing data period, substitute the maximum flow rate that the flowmeter can measure". IPL is seeking approval to establish the maximum flow for fuel to E.W. Stout GT-4 as the maximum amount of fuel the gas turbine is capable of burning. This issue was discussed with Mr. Pat Gimino and Ms. Margaret Sheppard prior to Pat's leave of absence from USEPA. During that conversation Pat and Margaret preliminarily agreed that the approach described below was reasonable and could be considered if further detail were provided in a letter.

Maximum oil and gas flow for GT-4 were determined using design values for peak load conditions. The results are summarized below.

<u>FUEL</u>	<u>METER RANGE</u>	<u>CALCULATED MAXIMUM FLOW</u>
OIL	1,500 - 15,000 gal/hr	8,731 gal/hr
GAS	0 - 138.5 - 150 in of H ₂ O	
	0 - 15.47 - ? lbs/sec	
	0 - 1,321 - ? kscf/hr	1,191 kscf/hr

The gas meter range contains three values on the same line. The first reading is the zero scale reading and the second reading is the flowmeter output at unit maximum load. The third reading is the maximum output of the flowmeter. To improve the accuracy over the operating range of the gas turbine, two differential pressure

Ms. Genevieve Nearmyer
June 14, 1994

Page 2

transducers are used in a split range configuration. The low range transducer is typically scaled at 0 - 30 inches of water and the upper range transducer 0 - 150 inches of water. GE has scaled the gas fuel metering system so that 19.5 - 138.5 inches of water corresponds to 25% of rated base load to maximum load.


As can be seen from the table above, the maximum water level of the fuel flow meter can exceed the amount of fuel the gas turbine can actually burn at peak load (calculated maximum flow). GT 4 is not capable of combusting fuel oil at natural gas in quantities shown as the maximum flow water range.

IPL proposes that for GT-4, 125% of the calculated maximum flow rate should be substituted for fuel flow during missing data periods. This would result in the following missing flow values:

TYPE	MISSING FLOW VALUE	MISSING FLOW VALUE
OIL	9,721 gal/hr x 1.25	-
GAS	1,191 kscf/hr x 1.25	-
		10,914 gal/hr
		1,489 kscf/hr

Copies of the calculations and supporting documents that they reference are enclosed. If you have any questions about this matter or feel additional discussion with IPL personnel would be useful, please contact me at (317) 261-8602.

Sincerely,



Lisa M. Tavorina

CALCULATIONS FOR MAXIMUM OIL FLOW

The calculations on this page use numbers supplied from three different documents. The General Electric Gas Turbine Estimated Performance sheet comes from the Operating Procedures manual supplied by the manufacturer. The box at the top of that page has design values for peak load conditions. We are using the design heat rate value for distillate. We are also using the maximum load limit contained in note 7.

Design Heat Rate (Distillate) = 10,520 btu/kwhr

Maximum Load = 115,000 kw

The second document is a fuel oil analysis performed by the Institute of Gas Technology on a sample taken at our combustion turbine. We are using the specific gravity and the gross heating values from the report.

Specific Gravity at 60/60 degf = .847

Heating Value (Gross) = 19,640 btu/lb

The third document is a conversion table to change specific gravity to density.

Specific Gravity (.847) = 7.053 lbs/gal

The first calculation multiplies unit maximum load by design heat rate at maximum load to get the amount of heat energy burned per hour.

$$115,000 \text{ kw} \times 10,520 \frac{\text{btu}}{\text{kwhr}} = 1,209,800,000 \frac{\text{btu}}{\text{hr}}$$

Next we divided the heat energy burned per hour at maximum load by the heating value (gross) of oil to get the number of pounds of oil burned per hour at maximum load.

$$\frac{1,209,800,000 \text{ btu/hr}}{19,640 \text{ btu/lb}} = 61,599 \frac{\text{lb}}{\text{hr}}$$

The third calculation divides the pounds of oil burned per hour at maximum load by the oil density to get the amount of oil burned at maximum load in gallons per hour.

$$\frac{61,599 \text{ lb/hr}}{7.053 \text{ lb/gal}} = 8,731 \frac{\text{gal}}{\text{hr}}$$

CALCULATIONS FOR MAXIMUM GAS FLOW

The calculations on this page use numbers supplied from two different documents. The General Electric Gas Turbine Estimated Performance sheet comes from the Operating Procedures manual supplied by the manufacturer. The box at the top of that page has design values for peak load conditions. We are using the design heat rate value for natural gas. We are also using the maximum load limit contained in note 7.

Design Heat Rate (Natural Gas) = 10,450 btu/kwhr

Maximum Load = 115,000 kw

The second document is a fuel gas analysis performed by the Institute of Gas Technology on a sample taken at our combustion turbine. We are using the gross heating value (saturated) from the report.

Gross Heating Value (Saturated) = 1,009 btu/scf

The first calculation multiplies unit maximum load by design heat rate at maximum load to get the amount of heat energy burned per hour.

$$115,000 \text{ kw} \times 10,450 \frac{\text{btu}}{\text{kwhr}} = 1,201,750,000 \frac{\text{btu}}{\text{hr}}$$

The second calculation divides the heat energy burned per hour at maximum load by the gross heating value (saturated) of gas and multiplies by a conversion factor to get the amount of gas burned at maximum load in thousands of standard cubic feet per hour.

$$\frac{1,201,750,000 \text{ btu/hr}}{1,009 \text{ btu/scf}} \times \frac{1 \text{ kscf}}{1,000 \text{ scf}} = 1,191 \frac{\text{kscf}}{\text{hr}}$$

GAS METER RANGE CONVERSION OF LBS/SEC TO KSCF/HR

$$15.47 \frac{\text{lb}}{\text{sec}} \times 379.5 \frac{\text{scf}}{\text{lb mole}} \times \frac{1 \text{ lb mole}}{16 \text{ lb}} \times 3600 \frac{\text{sec}}{\text{hr}} = 1,320,944 \frac{\text{scf}}{\text{hr}}$$

$$1,320,944 \frac{\text{scf}}{\text{hr}} \times \frac{1}{1000} \frac{\text{kscf}}{\text{scf}} = 1,321 \frac{\text{kscf}}{\text{hr}}$$

Gas Turbine

Operating Procedures

GENERAL ELECTRIC MODEL PG7111(EA) GAS TURBINE ESTIMATED PERFORMANCE - CONFIGURATION: NATURAL GAS & DISTILLATE

Compressor Inlet Conditions 59 F (15.0 C), 60% Rel. Humidity
Atmospheric Pressure 14.7 psia (1.013 bar)


FUEL			NATURAL GAS	DISTILLATE
DESIGN OUTPUT	kW		90200	88720
DESIGN HEAT RATE (LHV)	Btu (kJ)/kWh		10450 (11020)	10320 (11100)
DESIGN HEAT CONS (LHV)	Btu (kJ)/h		942.6 (994.4)	933.3 (984.7)
DESIGN EXHAUST FLOW	lb/h (kg)/h		2355 (1067)	2359 (1070)
MODE: PEAK LOAD				PPS 040486

NOTES:

- Altitude correction on curve 416HA862 REV A
- Ambient temperature correction on curve 516HA137
- Effect of modulated IGV's on exhaust flow and temp. on curve 516HA129
- Air cooled generator - 7AS
- Humidity correction on curve 490HA697 REV 8 - all performance calculated with specific humidity of .0064 or less so as not to exceed 100% relative humidity.
- Plant performance is measured at the generator terminals and includes allowances for excitation power, shaft driven auxiliaries, and 2.5 in. H₂O (6.2 mbar) inlet and 5.5 in. H₂O (13.7 mbar) exhaust pressure drops.
- Maximum load limit 115,000 kW.

B. Additional pressure drop effects:

	Effect on Output	Effect on Heat Rate	Effect on Exhaust Temp.
4 in. H ₂ O (10.0 mbar) inlet	-1.42	0.45	1.9 F (1.1 C)
4 in. H ₂ O (10.0 mbar) exhaust	-0.42	0.42	1.9 F (1.1 C)



DATE: 10/25/88
DA JACQUEWAY

516HA136

Page 3

IGT_ANALYTICAL

REPORT

Work Order # 94-04-001

Received: 04/01/94

Results by Sample

PLR ID Fuel oil sample

FRACTION 02A

TEST CODE 011

NAME Petroleum analysis

Date & Time Collected 03/25/94

Category

PHASE SEPARATION

Vol. (ml) %

Total Sample	:	ND
Oil	:	
Solids	:	
Water	:	
Solvent	:	

OIL FRACTION

Viscosity (Kinematic)	:	ND
(Saybolt)	:	ND

Pour Point (°F)	:	ND
-----------------	---	----

Specific Gravity by Hydrometer

(Degrees API at 60°F)	:	35.8
(Specific Gravity at 60/60°F)	:	0.847

Ash % (ASTM)	:		(Normalised)
(from OM detn.)	:	0.00	
Carbon %	:	86.87	86.45
Hydrogen %	:	13.57	13.58
Nitrogen %	:	0.02	
Sulfur %	:	0.03	
Oxygen %	:		
Total %	:	100.49	100.00

Carbon to Hydrogen Ratio	:	6.40
--------------------------	---	------

Heating Value (BTU/lb)

(Gross)	:	19640
(Net)	:	18610

Gross Enthalpy (BTU/lb) (-)	:	19620
-----------------------------	---	-------

Note: "ND" = Not Determined

Weight-Volume Relationships . . . continued

Degrees API

Degrees API	Specific Gravity at 60/60 F	Pounds Per Gallon	Gallons Per Pound	Degrees API	Specific Gravity at 60/60 F	Pounds Per Gallon	Gallons Per Pound	Degrees API	Specific Gravity at 60/60 F	Pounds Per Gallon	Gallons Per Pound	Degrees API	Specific Gravity at 60/60 F	Pounds Per Gallon	Gallons Per Pound
18.0	.9465	7.862	1269	25.0	.9042	7.638	1328	32.0	.8664	7.208	1388	39.0	.8289	6.910	1447
18.1	.9459	7.877	1270	25.1	.9036	7.624	1329	32.1	.8649	7.202	1389	39.1	.8294	6.906	1448
18.2	.9452	7.871	1270	25.2	.9030	7.619	1330	32.2	.8644	7.198	1390	39.2	.8299	6.902	1449
18.3	.9446	7.866	1271	25.3	.9024	7.614	1331	32.3	.8639	7.193	1391	39.3	.8304	6.898	1450
18.4	.9440	7.861	1272	25.4	.9018	7.609	1332	32.4	.8633	7.188	1391	39.4	.8309	6.894	1451
18.5	.9433	7.856	1273	25.5	.9012	7.605	1332	32.5	.8628	7.184	1392	39.5	.8314	6.890	1452
18.6	.9427	7.851	1274	25.6	.9007	7.600	1333	32.6	.8622	7.180	1393	39.6	.8319	6.886	1453
18.7	.9421	7.846	1275	25.7	.9001	7.596	1334	32.7	.8616	7.176	1394	39.7	.8324	6.882	1454
18.8	.9415	7.841	1275	25.8	.8996	7.591	1335	32.8	.8611	7.171	1395	39.8	.8329	6.878	1455
18.9	.9408	7.833	1276	25.9	.8990	7.586	1336	32.9	.8607	7.167	1396	39.9	.8334	6.874	1456
19.0	.9402	7.830	1277	26.0	.8984	7.581	1337	33.0	.8602	7.163	1396	40.0	.8339	6.870	1456
19.1	.9396	7.825	1278	26.1	.8978	7.576	1338	33.1	.8597	7.159	1397	40.1	.8344	6.866	1457
19.2	.9390	7.820	1278	26.2	.8972	7.572	1338	33.2	.8591	7.153	1398	40.2	.8349	6.862	1457