

The Following information regarding this incident has been reported:

Reporting Date: 8/5/2022 7:01:50 PM

Incident Date: 8/5/2022 @ 1:30 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Running Deer Road and Gage Irving Road Paso Robles, San Luis Obispo

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? No (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? Yes

Cause of Incident: Falling Tree (Other Cause:)

Agencies on Scene:

Facilities Affected:

- Utilities Facilities: Templeton 2110
- Voltage (KV): 21 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____ - _____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC PG&E Electrical Incident ? EI220805A - On August 5, 2022, a PG&E troubleman responded to a fire near Running Deer Road and Gage Irving Road in San Luis Obispo County. At the fire location, the PG&E troubleman observed that a tree had fallen into PG&E conductors on the Templeton 2110 21kV Distribution Circuit and was on fire. Firefighters extinguished the fire at approximately 1/2 acres. The incident resulted in an outage to 1,325 customers. A CAL FIRE fire investigator on site gave the PG&E troubleman a form that alleged that the fire was a result of the downed powerlines. PG&E is reporting this incident under the CPUC Media Incident Reporting Criteria. This information is preliminary.