

The Following information regarding this incident has been reported:

Reporting Date: 6/27/2022 4:01:13 PM

Incident Date: 6/23/2022 @ 1:55 p.m.

Reported By: [Redacted]

Utility Name: PG&E

Phone Number: [Redacted]

Email Address: [Redacted]

Incident Location: Timm Road and Buena Vista Lane Vacaville, Solano

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Fire (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: Vaca Dixon 1105
- Voltage (KV): 12 kV
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____)____-____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: CPUC Electric Incident EI220623A PG&E Law-Claims received a property damage claim in excess of \$50,000 from a customer in the vicinity of Timm Road and Buena Vista Lane, Vacaville of Solano County. The area is served by the Vaca Dixon 1105 12 kV primary overhead distribution circuit. The customer is claiming that on June 23, 2022 at 1355 hours, PG&E equipment started a vegetation fire which caused significant property damage. This incident is being reported under the property damage criterion. This information is preliminary.