



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Kimberly D. Shelley
Executive Director

DIVISION OF AIR QUALITY
Bryce C. Bird
Director

DAQE-AN103270030-22

December 5, 2022

Jon Finlinson
Intermountain Power Service Corporation
850 West Brush Wellman Road
Delta, UT 84624-9546
Mike.Utley@ipsc.com

Dear Mr. Finlinson:

Re: Approval Order:
Modification to Approval Order DAQE-AN103270029-22 to Correct a NO_x Limit Averaging
Period
Project Number: N103270030

The attached Approval Order (AO) is issued pursuant to the Notice of Intent (NOI) received on August 29, 2022. Intermountain Power Service Corporation must comply with the requirements of this AO, all applicable state requirements (R307), and Federal Standards.

The project engineer for this action is **John Jenks**, who can be contacted at (385) 306-6510 or jjenks@utah.gov. Future correspondence on this AO should include the engineer's name as well as the DAQE number shown on the upper right-hand corner of this letter. No public comments were received on this action.

Sincerely,

Bryce C. Bird
Director

BCB:JJ:jg

cc: Central Utah Health Department
Dan Fagnant, EPA Region 8

STATE OF UTAH
Department of Environmental Quality
Division of Air Quality

APPROVAL ORDER
DAQE-AN103270030-22
Modification to Approval Order DAQE-AN103270029-22
to Correct a NO_x Limit Averaging Period

Prepared By
John Jenks, Engineer
(385) 306-6510
jjenks@utah.gov

Issued to
Intermountain Power Service Corporation - Intermountain Generation
Station

Issued On
December 5, 2022

Issued By



Bryce C. Bird
Director
Division of Air Quality

TABLE OF CONTENTS

TITLE/SIGNATURE PAGE	1
GENERAL INFORMATION	3
CONTACT/LOCATION INFORMATION	3
SOURCE INFORMATION.....	3
General Description	3
NSR Classification.....	3
Source Classification	3
Applicable Federal Standards	3
Project Description.....	4
SUMMARY OF EMISSIONS.....	4
SECTION I: GENERAL PROVISIONS	5
SECTION II: PERMITTED EQUIPMENT	5
SECTION II: SPECIAL PROVISIONS.....	11
PERMIT HISTORY	18
ACRONYMS	19

GENERAL INFORMATION

CONTACT/LOCATION INFORMATION

Owner Name

Intermountain Power Service Corporation

Source Name

Intermountain Power Service Corporation -
Intermountain Generation Station

Mailing Address

850 West Brush Wellman Road
Delta, UT 84624-9546

Physical Address

850 West Brush Wellman Road
Delta, UT 84624-9546

Source Contact

Name Mike Utley
Phone (435) 864-6489
Email Mike.Utley@ipsc.com

UTM Coordinates

364136.12 m Easting
4374604.80 m Northing
Datum NAD27
UTM Zone 12

SIC code 4911 (Electric Services)

SOURCE INFORMATION

General Description

Intermountain Power Agency (IPA) operates the Intermountain Generating Station facility in Delta, Utah. Intermountain Generating Station consists of two (2) coal-fired electric utility steam generating units and the ancillary facilities to support their normal operation. The units are dry bottom, wall-fired boilers with a nominal capacity of 9,225 MMBtu/hr each. These units will be replaced with two 487 MW natural-gas/hydrogen fueled CCCT units controlled with selective catalytic reduction (SCR). The plant is a Phase II Acid Rain source and is a major source of SO₂, NO_x, PM₁₀, PM_{2.5}, CO, HAP, and HCl emissions.

NSR Classification

Minor Modification at Major Source

Source Classification

Located in Attainment Area
Millard County
Airs Source Size: A

Applicable Federal Standards

NSPS (Part 60), A: General Provisions
NSPS (Part 60), Da: Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978
NSPS (Part 60), Db: Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units
NSPS (Part 60), Dc: Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units
NSPS (Part 60), Y: Standards of Performance for Coal Preparation and Processing Plants

NSPS (Part 60), IIII: Standards of Performance for Stationary Compression Ignition Internal Combustion Engines
 NSPS (Part 60), KKKK: Standards of Performance for Stationary Combustion Turbines
 NSPS (Part 60), TTTT: Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units
 MACT (Part 63), A: General Provisions
 MACT (Part 63), ZZZZ: National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines
 MACT (Part 63), DDDDD: National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters
 MACT (Part 63), UUUUU: National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-Fired Electric Utility Steam Generating Units
 MACT (Part 63), JJJJJ: National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources
 Title IV (Part 72 / Acid Rain)
 Title V (Part 70) Major Source

Project Description

When the AO DAQE-AN103270029-22 was issued, an inadvertent error was included in the averaging period for the NO_x limit on the new combustion turbines. Rather than including the correct 30-day rolling period established as BACT, an erroneous averaging period of 3-hours was listed. This permitting action is to rectify this error. As this could potentially be viewed as a relaxation of a permit term, a 30-day public comment period is required prior to making this change. No other changes are anticipated as part of this permitting action.

SUMMARY OF EMISSIONS

The emissions listed below are an estimate of the total potential emissions from the source. Some rounding of emissions is possible.

Criteria Pollutant	Change (TPY)	Total (TPY)
CO ₂ Equivalent	0	3,997,196
Carbon Monoxide	0	236.51
Lead	0	0.00
Nitrogen Oxides	0	286.92
Particulate Matter - PM ₁₀	0	112.57
Particulate Matter - PM _{2.5}	0	108.29
Sulfur Dioxide	0	128.90
Volatile Organic Compounds	0	82.09

Hazardous Air Pollutant	Change (lbs/yr)	Total (lbs/yr)
Beryllium (TSP) (CAS #7440417)	0	0
Generic HAPs (CAS #GHAPS)	0	35560
Hydrochloric Acid (Hydrogen Chloride) (CAS #7647010)	0	0
Lead (CAS #7439921)	0	0
Mercury (Organic) (CAS #22967926)	0	0
	Change (TPY)	Total (TPY)
Total HAPs	0	17.78

SECTION I: GENERAL PROVISIONS

I.1	All definitions, terms, abbreviations, and references used in this AO conform to those used in the UAC R307 and 40 CFR. Unless noted otherwise, references cited in these AO conditions refer to those rules. [R307-101]
I.2	The limits set forth in this AO shall not be exceeded without prior approval. [R307-401]
I.3	Modifications to the equipment or processes approved by this AO that could affect the emissions covered by this AO must be reviewed and approved. [R307-401-1]
I.4	All records referenced in this AO or in other applicable rules, which are required to be kept by the owner/operator, shall be made available to the Director or Director's representative upon request, and the records shall include the two-year period prior to the date of the request. Unless otherwise specified in this AO or in other applicable state and federal rules, records shall be kept for a minimum of five years. [R307-401-8]
I.5	At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any equipment approved under this AO, including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Director which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source. All maintenance performed on equipment authorized by this AO shall be recorded. [R307-401-4]
I.6	The owner/operator shall comply with UAC R307-107. General Requirements: Breakdowns. [R307-107]
I.7	The owner/operator shall comply with UAC R307-150 Series. Emission Inventories. [R307-150]
I.8	The owner/operator shall submit documentation of the status of construction of the new Combustion Turbine Plant equipment (II.A.3 through II.A.9) to the Director by December 22, 2023. This AO may become invalid if construction is not commenced within 18 months from the date of this AO or if construction is discontinued for 18 months or more. To ensure proper credit when notifying the Director, send the documentation to the Director, attn.: NSR Section. [R307-401-18]

SECTION II: PERMITTED EQUIPMENT

II.A THE APPROVED EQUIPMENT

II.A.1	Electric Plant Combustion turbine plant, coal-fired boiler plant, emergency equipment, etc.
II.A.2	Combustion Turbine Plant Equipment The following items are located at the new combustion turbine plant

II.A.3	<p>Combined Cycle Combustion Turbines Two (2) 487 MW natural gas and hydrogen-fired combined-cycle combustion turbines Control: SCR and oxidation catalyst</p>
II.A.4	<p>Fuel Gas Heaters Two (2) 9.9 MMBtu/hr natural gas-fired heaters</p>
II.A.5	<p>Auxiliary Boiler 136 MMBtu/hr natural gas-fired auxiliary boiler Control: Low-NO_x Burner (0.14 lb/MMBtu)</p>
II.A.6	<p>Cooling Towers Two (2) six-cell linear mechanical draft cooling towers (LMDCTs) 88,341 gpm of cooling water per tower</p>
II.A.7	<p>Emergency Generators Three (3) diesel-fired emergency generators Rating: 2,500 kW Each NSPS Applicability: Subpart III MACT Applicability: Subpart ZZZZ</p>
II.A.8	<p>Firewater Pump One (1) 425 bhp diesel-fired emergency firewater pump engine</p>
II.A.9	<p>Miscellaneous Fugitive Sources Natural gas piping components (pipes, flanges, valves, etc.) New circuit breakers located at switchyard - SF6 insulated, air cooled.</p>
II.A.10	<p>Existing Equipment The following existing equipment (II.A.11 through II.A.31) will remain available for operation at the site following installation of the new turbine plant</p>
II.A.11	<p>#1 Lime Dust Collector Dust collector controlling the lime silo</p>
II.A.12	<p>#2 Lime Dust Collector Dust collector controlling the lime hopper</p>
II.A.13	<p>#3 Soda Ash Dust Collector Dust collector controlling the soda ash silo</p>
II.A.14	<p>#4 Soda Ash dust Collector Dust collector controlling the soda ash hopper</p>
II.A.15	<p>Paved Haul Roads</p>
II.A.16	<p>Landfill Class III Industrial Waste Landfill</p>
II.A.17	<p>Gasoline Tank Capacity: 500 gallons</p>
II.A.18	<p>Diesel Tank Capacity: 10,000 gallons</p>

II.A.19	Diesel Day Tanks Maximum capacity: Not to exceed 560 gallons per tank
II.A.20	Mobile Oil Storage Tanks Maximum capacity: Not to exceed 12,000 gallons per tank
II.A.21	Used Oil Tank Capacity: 10,000 gallons
II.A.22	On-Road Diesel Tank Non-commercial, ultra-low sulfur, highway diesel fuel tank Capacity: 500 gallons
II.A.23	Paint booth/shops
II.A.24	Solvent Washer
II.A.25	Bulb recycling crusher
II.A.26	Emergency diesel-driven fire pump Diesel fire pump located at the Intermountain Community Center, but operated by IPP. Rating: 290 HP
II.A.27	Engine Driven Equipment Compressors, generators, hydraulic pumps and diesel fire pumps
II.A.28	Unpaved Haul Roads
II.A.29	#1B Fire Pump Diesel driven fire pump Rating: 290 hp
II.A.30	#1C Fire Pump Diesel driven fire pump Rating: 290 hp
II.A.31	ICS Cooling Towers Eight (8) cooling towers used at the Intermountain Converter Station and auxiliary equipment
II.A.32	Coal-fired Boiler Plant Equipment The following equipment (II.A.32 - II.A.87) is considered part of the coal-fired boiler plant and will be removed from service once the combustion turbine plant is operational
II.A.33	Unit #1 Coal Fired Boiler Equipped with low NO _x burners with a maximum heat input of 248 MMBtu/hr per burner. Rating - 9,225,000,000 MMBtu/yr
II.A.34	Unit #2 Coal Fired Boiler Equipped with low NO _x burners with a maximum heat input of 248 MMBtu/hr per burner. Rating - 9,225,000,000 MMBtu/yr
II.A.35	Over-Fire Air-Port System Boiler #1 & #2 over-fire air-ports system, 16 per boiler
II.A.36	#1A Dust Collector Dust collector controlling coal railcar unloading

II.A.37	#1B Dust Collector Dust collector controlling coal railcar unloading
II.A.38	#1C Dust Collector Dust collector controlling coal railcar unloading
II.A.39	#1D Dust Collector Dust collector controlling coal railcar unloading
II.A.40	#4 Coal Dust Collector Dust collector controlling Coal transfer building #1
II.A.41	#5 Coal Dust Collector Dust collector controlling coal transfer building #2
II.A.42	#6 Coal Dust Collector Dust collector controlling coal transfer building #4
II.A.43	#11 Coal Dust Collector Dust collector controlling coal crusher building
II.A.44	#13A Coal Dust Collector Dust collector controlling U1 Generation building coal dust
II.A.45	#13B Coal Dust Collector Dust collector controlling U1 Generation building coal dust
II.A.46	#14A Coal Dust Collector Dust collector controlling U2 Generation building coal dust
II.A.47	#14B Coal Dust Collector Dust collector controlling U2 Generation building coal dust
II.A.48	#4 Limestone Dust Collector Dust collector controlling limestone preparation
II.A.49	#2 Coal Dust Collector Dust collector controlling Coal truck unloading
II.A.50	#3 Coal Dust Collector Dust collector controlling coal reserve reclaim
II.A.51	#1A Limestone Dust Collector Dust collector controlling limestone unloading
II.A.52	#1B Limestone Dust Collector Dust collector controlling limestone unloading
II.A.53	#1 Limestone Dust Collector Dust collector controlling limestone transfer
II.A.54	#2 Limestone Dust Collector Dust collector controlling limestone reclaim
II.A.55	Limestone silo bin vent filter

II.A.56	#3 Limestone Dust Collector Dust collector controlling limestone crusher
II.A.57	#1A Filter Fly ash silo bin vent filter
II.A.58	#1B Filter Fly ash silo bin vent filter
II.A.59	Coal sample preparation building dust collector
II.A.60	Sandblast facility dust collector
II.A.61	Dust Collector Dust collector controlling U1 Generation building vacuum cleaning
II.A.62	Dust Collector Dust collector controlling U2 Generation building vacuum cleaning
II.A.63	Dust Collector Dust collector controlling U1 Fabric filter vacuum cleaning
II.A.64	Dust Collector Dust collector controlling U2 Fabric filter vacuum cleaning
II.A.65	Dust Collector Dust collector controlling GSB vacuum cleaning
II.A.66	Coal Pile Active and reserve
II.A.67	Coal Stackout
II.A.68	#1A Tank Fuel oil tank Capacity: 675,000 gallons
II.A.69	#1B Tank Fuel oil tank Capacity: 675,000 gallons
II.A.70	Limestone storage pile
II.A.71	Combustion byproducts stackout & stockpile
II.A.72	Combustion byproducts landfill
II.A.73	#1A Cooling Tower Unit 1 cooling tower
II.A.74	#1B Cooling Tower Unit 1 cooling tower
II.A.75	#1A Cooling Tower Unit 2 cooling tower

II.A.76	#1B Cooling Tower Unit 2 cooling tower
II.A.77	#1A Generator Emergency generator Rating:* 4,000 hp
II.A.78	#1B Generator Emergency generator Rating: 4,000 hp
II.A.79	#1C Generator Emergency generator, Rating: 4,000 hp
II.A.80	Engine Driven Equipment Compressors and hydraulic pumps
II.A.81	Coal Conveyors
II.A.82	Coal Truck Unloading Grating
II.A.83	Laboratory fume hoods
II.A.84	Turbine Lube Oil Units Maximum capacity: Not to exceed 40,000 gallons per tank
II.A.85	Diesel Tank Underground storage diesel tank Capacity: 20,000 gallons
II.A.86	Gasoline Tank Underground storage gasoline tank Capacity: 6,000 gallons
II.A.87	Two Helper Cooling Towers

SECTION II: SPECIAL PROVISIONS

II.B REQUIREMENTS AND LIMITATIONS

II.B.1	Intermountain Generating Station
II.B.1.a	<p>Visible emissions from the following emission point sources shall not exceed the listed values:</p> <p>A. All abrasive blasting - 40% opacity (grandfathered equipment)</p> <p>B. All other points - 20% opacity</p> <p>Opacity observations of emissions from stationary sources shall be conducted according to 40 CFR 60, Appendix A, Method 9.</p> <p>For sources that are subject to NSPS, except for the units equipped with continuous opacity monitoring system, opacity shall be determined by conducting observations in accordance with 40 CFR 60.11(b) and 40 CFR 60, Appendix A, Method 9.</p> <p>[R307-201-3]</p>
II.B.1.b	<p>The owner/operator shall abide by the latest FDCP submitted to the Director for control of all dust sources associated with the Intermountain Power Generation site.</p> <p>Any haul road speeds established in the plan shall be posted. [R307-205]</p>
II.B.1.c	<p>The facility shall abide by all applicable requirements of R307-205 for Fugitive Emission and Fugitive Dust sources. [R307-205]</p>
II.B.2	Stack Testing Requirements
II.B.2.a	<p>The owner/operator shall conduct any stack testing required by this AO according to the following conditions. [R307-401-8]</p>
II.B.2.a.1	<p>Notification</p> <p>At least 30 days prior to conducting a stack test, the owner/operator shall submit a source test protocol to the Director. The source test protocol shall include the items contained in R307-165-3. If directed by the Director, the owner/operator shall attend a pretest conference. [R307-165-3, R307-401-8]</p>
II.B.2.a.2	<p>Testing & Test Conditions</p> <p>The owner/operator shall conduct testing according to the approved source test protocol and according to the test conditions contained in R307-165-4. [R307-165-4, R307-401-8]</p>
II.B.2.a.3	<p>Access</p> <p>The owner/operator shall provide Occupational Safety and Health Administration (OSHA)- or Mine Safety and Health Administration (MSHA)-approved access to the test location. [R307-401-8]</p>
II.B.2.a.4	<p>Reporting</p> <p>No later than 60 days after completing a stack test, the owner/operator shall submit a written report of the results from the stack testing to the Director. The report shall include validated results and supporting information. [R307-165-5, R307-401-8]</p>
II.B.2.a.5	<p>Possible Rejection of Test Results</p> <p>The Director may reject stack testing results if the test did not follow the approved source test protocol or for a reason specified in R307-165-6. [R307-165-6, R307-401-8]</p>

II.B.2.b	<p>Test Methods When performing stack testing, the owner/operator shall use the appropriate EPA-approved test methods as acceptable to the Director. Acceptable test methods for pollutants are listed below. [R307-401-8]</p>
II.B.2.b.1	<p>Standard Conditions</p> <p>A. Temperature - 68 degrees Fahrenheit (293 K)</p> <p>B. Pressure - 29.92 in Hg (101.3 kPa)</p> <p>C. Averaging Time - As specified in the applicable test method</p> <p>[40 CFR 60 Subpart A, 40 CFR 63 Subpart A, R307-401-8]</p>
II.B.2.b.2	<p>PM₁₀ Total PM₁₀ = Filterable PM₁₀ + Condensable PM</p> <p>Filterable PM₁₀ 40 CFR 60, Appendix A, Method 5; 40 CFR 51, Appendix M, Method 201; Method 201A; or other EPA-approved testing method as acceptable to the Director. If other approved testing methods are used which cannot measure the PM₁₀ fraction of the filterable particulate emissions, all of the filterable particulate emissions shall be considered PM₁₀.</p> <p>Condensable PM 40 CFR 51, Appendix M, Method 202 or other EPA-approved testing method as acceptable to the Director.</p> <p>[R307-401-8]</p>
II.B.2.b.3	<p>NO_x 40 CFR 60, Appendix A, Method 7; Method 7E; or other EPA-approved testing method as acceptable to the Director. [R307-401-8]</p>
II.B.2.b.4	<p>SO₂ 40 CFR 60, Appendix A, Method 6; Method 6C; or other EPA-approved testing method as acceptable to the Director. [R307-401-8]</p>
II.B.2.b.5	<p>CO 40 CFR 60, Appendix A, Method 10 or other EPA-approved testing method as acceptable to the Director. [R307-401-8]</p>
II.B.2.b.6	<p>VOC 40 CFR 60, Appendix A, Method 18; Method 25; Method 25A; 40 CFR 63, Appendix A, Method 320; or other EPA-approved testing method as acceptable to the Director. [R307-401-8]</p>
II.B.2.b.7	<p>Existing Source Operation: For an existing source/emission point, the production rate during all compliance testing shall be no less than 90% of the maximum production achieved in the previous three (3) years. [R307-401-8]</p>

II.B.3	Combustion Turbine Plant												
II.B.3.a	<p>The owner/operator shall install, calibrate, maintain, and operate a continuous emissions monitoring system on each of the HRSG stacks. The owner/operator shall record the NO_x and CO emissions. The monitoring system shall comply with all applicable sections of R307-170; 40 CFR 13; and 40 CFR 60, Appendix B. The NO_x monitor shall comply with 40 CFR 75, Appendix A and B.</p> <p>All continuous emissions monitoring devices as required in federal regulations and state rules shall be installed prior to placing the affected source in operation. These devices shall be certified within 90 days of achieving full load, not to exceed 180 days after startup.</p> <p>Except for system breakdown, repairs, calibration checks, and zero and span adjustments required under paragraph (d) 40 CFR 60.13, the owner/operator of an affected source shall continuously operate all required continuous monitoring systems and shall meet minimum frequency of operation requirements as outlined in R307-170 and 40 CFR 60.13.</p> <p>[40 CFR 60.13, R307-170]</p>												
II.B.3.b	<p>The owner/operator shall use natural gas or hydrogen (H₂) as fuel in the combustion turbines.</p> <p>The owner/operator shall use natural gas as fuel in the auxiliary boiler.</p> <p>[R307-401-8(1)(a)]</p>												
II.B.3.c	<p>The owner/operator shall not exceed 535 million standard cubic feet (SCF) natural gas consumption at the 136 MMBtu/hr Auxiliary Boiler (II.A.5) per rolling 12-month period.</p> <p>[R307-401-8(1)(a)]</p>												
II.B.3.c.1	<p>Natural gas consumption shall be monitored through use of a flow meter on the natural gas supply line to the Auxiliary Boiler. Fuel usage shall be determined and recorded monthly. By the 20th day of each month a new rolling 12-month total shall be calculated by summing the monthly fuel usage values for the previous 12 months. Monthly and total 12-month fuel usage shall be recorded in an operations log. [R307-401-8]</p>												
II.B.3.d	<p>Emissions to the atmosphere from each Turbine/HRSG Stack shall not exceed the following rates and concentrations:</p> <table border="0" data-bbox="349 1283 1128 1402"> <thead> <tr> <th>Pollutant</th> <th>Limitations</th> <th>Averaging Period</th> </tr> </thead> <tbody> <tr> <td>NO_x</td> <td>2.0 ppmvd at 15% O₂ *</td> <td>30-day rolling</td> </tr> <tr> <td>CO</td> <td>2.0 ppmvd at 15% O₂ *</td> <td>3-hour</td> </tr> <tr> <td>VOC</td> <td>1.0 ppmvd at 15% O₂ *</td> <td>3-hour</td> </tr> </tbody> </table> <p>* Under steady state operation. [R307-401-8(1)(a)]</p>	Pollutant	Limitations	Averaging Period	NO _x	2.0 ppmvd at 15% O ₂ *	30-day rolling	CO	2.0 ppmvd at 15% O ₂ *	3-hour	VOC	1.0 ppmvd at 15% O ₂ *	3-hour
Pollutant	Limitations	Averaging Period											
NO _x	2.0 ppmvd at 15% O ₂ *	30-day rolling											
CO	2.0 ppmvd at 15% O ₂ *	3-hour											
VOC	1.0 ppmvd at 15% O ₂ *	3-hour											

<p>II.B.3.d.1</p>	<p>Stack testing to demonstrate compliance with the emission limitations stated in the above condition shall be performed on the following schedule:</p> <p>Each turbine/HRSG stack</p> <p>NO_x: compliance shall be demonstrated by CEM as outlined in condition II.B.3.a. The Director may require testing at any time.</p> <p>CO: compliance shall be demonstrated by CEM as outlined in condition II.B.3.a. The Director may require testing at any time.</p> <p>VOC: initial testing is required within 180 days of beginning operation, subsequent testing to be conducted at least once annually. Testing may be replaced with parametric monitoring if approved by the Director.</p> <p>[R307-165, R307-170]</p>
<p>II.B.3.d.2</p>	<p>Steady state operation means all periods of combustion turbine operation, except for periods of startup and shutdown as defined below. Startup is defined as the period beginning with turbine initial firing until the unit meets the ppmvd emission limits listed in condition II.B.3.d for steady state operation. Shutdown is defined as the period beginning with the initiation of turbine shutdown sequence and ending with the cessation of firing of the gas turbine engine.</p> <p>The owner/operator shall ensure the following limitations:</p> <ol style="list-style-type: none"> 1. Startup and shutdown events shall not exceed 114.9 hours per turbine per rolling 12-month period and are counted toward the applicable annual emission limitations. 2. Emissions of NO_x from either turbine/HRSG stack shall not exceed 100.8 lb/hr during startup or shutdown operations. 3. Emissions of CO from either turbine/HRSG stack shall not exceed 624.0 lb/hr during startup or shutdown operations. <p>Compliance with the hours of operation limitation shall be determined through maintenance of an operations log detailing the mode of operation and total hours of operation in each mode.</p> <p>Compliance with the NO_x and CO emission limits shall be determined by CEM as outlined in II.B.3.a.</p> <p>[R307-401-8(1)(a)]</p>
<p>II.B.4</p>	<p>Emergency Engine Requirements</p>
<p>II.B.4.a</p>	<p>The owner/operator shall install emergency engines (II.A.7) that are certified to meet a NO_x emission rate of 7.29 g/kW-hr or less. [R307-401-8(1)(a)]</p>
<p>II.B.4.a.1</p>	<p>To demonstrate compliance with the emission rate, the owner/operator shall keep a record of the manufacturer's certification of emission standards. The record shall be kept for the life of the equipment. [R307-401-8]</p>
<p>II.B.4.b</p>	<p>The owner/operator shall not operate each emergency engine on site for more than 100 hours per rolling 12-month period during non-emergency situations. There is no time limit on the use of the engines during emergencies. [40 CFR 63 Subpart ZZZZ, R307-401-8]</p>

II.B.4.b.1	<p>To determine compliance with a rolling 12-month total, the owner/operator shall calculate a new 12-month total by the 20th day of each month using data from the previous 12 months. Records documenting the operation of each emergency engine shall be kept in a log and shall include the following:</p> <ul style="list-style-type: none"> A. The date the emergency engine was used B. The duration of operation in hours C. The reason for the emergency engine usage. <p>[40 CFR 60 Subpart ZZZZ, R307-401-8]</p>
II.B.4.b.2	<p>To determine the duration of operation, the owner/operator shall install a non-resettable hour meter for each emergency engine (generator or fire water pump). [40 CFR 60 Subpart ZZZZ, R307-401-8]</p>
II.B.4.c	<p>The owner/operator shall only use diesel fuel (e.g. fuel oil #1, #2, or diesel fuel oil additives) as fuel in each emergency engine (generator or fire water pump). [R307-401-8]</p>
II.B.4.c.1	<p>The owner/operator shall only combust diesel fuel that meets the definition of ultra-low sulfur diesel (ULSD), which has a sulfur content of 15 ppm or less. [R307-401-8]</p>
II.B.4.c.2	<p>To demonstrate compliance with the ULSD fuel requirement, the owner/operator shall maintain records of diesel fuel purchase invoices or obtain certification of sulfur content from the diesel fuel supplier. The diesel fuel purchase invoices shall indicate that the diesel fuel meets the ULSD requirements. [R307-401-8]</p>
II.B.5	<p>Coal Plant Sunset Provisions</p>
II.B.5.a	<p>The equipment listed in Section II.A.32 under the heading Coal-fired Boiler Plant Equipment shall remain in operation until such time as the new combustion turbines are installed and operational. The new Combustion Turbine Plant will become operational only after a reasonable shakedown period, not to exceed 180 days. At that time the listed Coal Boiler Plant Equipment shall cease operations and be removed from service.</p> <p>Conditions II.B.6 through II.B.7.a, shall not apply to the owner/operator once the equipment has been removed from service.</p> <p>[R307-401]</p>
II.B.6	<p>Unit #1 & Unit #2 Main Boilers</p>
II.B.6.a	<p>The owner/operator shall combust only bituminous, subbituminous coals, non-limited synthetic coal-derived fuels and refined coal (synfuels), as primary fuels and shall only use diesel oil or natural gas during the startups, shutdowns, maintenance, performance tests, upsets and for flame stabilization in the 9,225 MMBtu/hr boilers. The owner/operator may fuel-blend self-generated used oil with coal at the active coal pile reclaim structure provided that self-generated used oil has not been mixed with hazardous waste. [R307-401]</p>
II.B.6.a.1	<p>The sulfur content of any fuel oil combusted shall not exceed 0.85 lb/MMBtu heat input in the main boilers. The sulfur content shall be determined by ASTM Method D-4294-89 or approved equivalent. Certification of fuel oil shall either be by IPSCs own testing or test reports from the fuel oil marketer. [R307-203]</p>

<p>II.B.6.b</p>	<p>The owner/operator shall install, calibrate, maintain, and operate a continuous emissions monitoring system (CEMS) on the main boiler stacks and SO₂ removal scrubber inlets. The owner/operator shall record the output of the system, for measuring the opacity, SO₂, NO_x, and CO₂ emissions. The monitoring system shall comply with all applicable sections of R307-170, UAC; and 40 CFR 60, Appendix B.</p> <p>All continuous emissions monitoring devices as required in federal regulations and state rules shall be installed and operational prior to placing the affected source in operation.</p> <p>Except for system breakdown, repairs, calibration checks, and zero and span adjustments required under paragraph (d) 40 CFR 60.13, the owner/operator of an affected source shall continuously operate all required continuous monitoring devices and shall meet minimum frequency of operation requirements as outlined in 40 CFR 60.13 and Section UAC R307-170. [R307-150]</p>								
<p>II.B.6.c</p>	<p>Unit #1 & Unit #2 Main Boiler Stack</p> <p>Except for time of start-up, shut-down, malfunction (NO_x or PM₁₀ only), or emergency conditions (SO₂ only), emissions to the atmosphere at all times from the indicated emission points shall not exceed the following rates and concentrations:</p> <table border="0" data-bbox="349 808 1047 955"> <thead> <tr> <th>Pollutant</th> <th>lb/MMBtu heat input</th> </tr> </thead> <tbody> <tr> <td>PM₁₀</td> <td>0.0184*</td> </tr> <tr> <td>SO₂</td> <td>0.138 ** (based on 30-day rolling average)</td> </tr> <tr> <td>NO_x</td> <td>0.461 ** (based on 30-day rolling average)</td> </tr> </tbody> </table> <p>* Test once a year. The Director may require testing at any time. ** Compliance for NO_x and SO₂ emissions shall be demonstrated through use of a continuous emissions monitoring system as outlined in Condition II.B.6.b. [R307-401]</p>	Pollutant	lb/MMBtu heat input	PM ₁₀	0.0184*	SO ₂	0.138 ** (based on 30-day rolling average)	NO _x	0.461 ** (based on 30-day rolling average)
Pollutant	lb/MMBtu heat input								
PM ₁₀	0.0184*								
SO ₂	0.138 ** (based on 30-day rolling average)								
NO _x	0.461 ** (based on 30-day rolling average)								

<p>II.B.6.c.1</p>	<p>Calculations for Test Results: Unit #1 & Unit #2 Boiler Stacks</p> <p>To determine mass emission rates (lb/hr, etc.) the pollutant concentration as determined by the appropriate methods above shall be multiplied by the volumetric flow rate and any necessary conversion factors determined by the Director, to give the results in the specified units of the emission limitation.</p> <p>Pollutant lbs/hr (Compliance demonstration)</p> <p>CO 1320 lb/hr rate (monthly block average)</p> <p>Combustion flue gas percent O₂ shall be monitored and recorded at least once per 15 minutes at the exit path of each boiler. Measurements are weighted average results collected from several sensors located in each boiler exit flue path. Calibrations shall be maintained within manufacturer's recommendations.</p> <p>Over-Fire Air (OFA) operating condition shall be monitored and recorded at least once per 15 minutes. Monitoring shall include OFA position and status: i.e., No OFA, 1/3 OFA, 2/3 OFA, throttled or open. Operational status is measured by OFA system damper position.</p> <p>Using the data above and this formula, CO concentration (ppmvd) shall be calculated and averaged hourly, except for periods of calibration, maintenance, or malfunction of the instrumentation or data system. For periods of calibration, maintenance, or malfunction of instrumentation or data collection system, missing data shall be back filled following procedures similar to 40 CFR Part 75 Subpart D, and used for compliance determinations.</p> <p>$[C_{ppmvd}] = n * (O_2\%)^a$</p> <p>Where: [C_{ppmvd}] = concentration of CO in parts per million volume dry n = curve specific factor obtained from the table below O₂% = percent O₂ measured at the boiler stack exit a = curve specific exponent obtained from the table below</p> <p>Values for n and a factors:</p> <table border="1"> <thead> <tr> <th></th> <th>n</th> <th>a</th> </tr> </thead> <tbody> <tr> <td>No. OFA</td> <td>47259</td> <td>-7.6817</td> </tr> <tr> <td>1/3 OFA</td> <td>66265</td> <td>-7.9824</td> </tr> <tr> <td>2/3 OFA (Throttled)</td> <td>4029.2</td> <td>-4.0112</td> </tr> <tr> <td>2/3 OFA (full open)</td> <td>1372.4</td> <td>-3.0919</td> </tr> </tbody> </table> <p>The hourly mass emission rates in lb per hour shall be calculated using the following formula or any necessary conversion factors determined by the Director, to give the results in the specified units of the emission limitation.</p> <p>$[C_{lb/hr}] = [C_{ppmvd}] * 2.59 * 10E-9 * MW * Fd * 20.9 / (20.9 - O_2\%) * HI$</p> <p>Where: [C_{lb/hr}] = pound per hour emission rate [C_{ppmvd}] = hourly average of CO emissions in parts per million 2.59*10E-9 = conversion factor for pound per standard cubic feet MW = molecular weight of CO Fd = F factor to convert standard cubic feet per MMBtu heat input. O₂% = hourly average of excess combustion oxygen, in percent HI = heat input, in MMBtu per hour</p> <p>By the 15th day of each month, the monthly average of CO emissions in lb/hr shall be calculated by using the hourly average CO emission values in lb/hr.</p> <p>[R307-401]</p>		n	a	No. OFA	47259	-7.6817	1/3 OFA	66265	-7.9824	2/3 OFA (Throttled)	4029.2	-4.0112	2/3 OFA (full open)	1372.4	-3.0919
	n	a														
No. OFA	47259	-7.6817														
1/3 OFA	66265	-7.9824														
2/3 OFA (Throttled)	4029.2	-4.0112														
2/3 OFA (full open)	1372.4	-3.0919														

II.B.6.d	The owner/operator shall comply with R307-424 Permits: Mercury Requirements for Electric Generating Units. [R307-424-4]																						
II.B.7	Dust Collectors																						
II.B.7.a	<p>Except for times of start-up, shut-down, or malfunction, differential pressure at the indicated emission points, at all times, shall be within the following limits:</p> <table border="0"> <thead> <tr> <th data-bbox="349 409 544 462">Pollutant/Source PM₁₀</th> <th data-bbox="730 409 1364 462">Differential Pressure Range Across the Dust Collector (Inches of water gage)</th> </tr> </thead> <tbody> <tr> <td data-bbox="349 493 673 525">(4) Rail car unloading units</td> <td data-bbox="820 493 933 525">0.5 to 12</td> </tr> <tr> <td data-bbox="349 525 592 556">Transfer building #1</td> <td data-bbox="820 525 933 556">0.5 to 12</td> </tr> <tr> <td data-bbox="349 556 592 588">Transfer building #2</td> <td data-bbox="820 556 933 588">0.5 to 12</td> </tr> <tr> <td data-bbox="349 588 592 619">Transfer building #4</td> <td data-bbox="820 588 933 619">0.5 to 12</td> </tr> <tr> <td data-bbox="349 619 592 651">Crusher building #1</td> <td data-bbox="820 619 933 651">0.5 to 12</td> </tr> <tr> <td data-bbox="349 651 511 682">Unit one 13A</td> <td data-bbox="820 651 933 682">0.5 to 12</td> </tr> <tr> <td data-bbox="349 682 511 714">Unit one 13B</td> <td data-bbox="820 682 933 714">0.5 to 12</td> </tr> <tr> <td data-bbox="349 714 511 745">Unit two 14A</td> <td data-bbox="820 714 933 745">0.5 to 12</td> </tr> <tr> <td data-bbox="349 745 511 777">Unit two 14B</td> <td data-bbox="820 745 933 777">0.5 to 12</td> </tr> <tr> <td data-bbox="349 777 722 808">Limestone preparation building</td> <td data-bbox="820 777 933 808">0.5 to 12</td> </tr> </tbody> </table> <p>If any differential pressure is less than 2 inches or greater than 10 inches, work orders will be written to investigate. Dust collector may run in the 0.5 to 2 or 10 to 12 range if reason is known. Intermittent recording of the reading is required on a monthly basis. The instrument shall be calibrated against a primary standard annually. Preventive maintenance shall be done quarterly on each baghouse. [R307-401]</p>	Pollutant/Source PM ₁₀	Differential Pressure Range Across the Dust Collector (Inches of water gage)	(4) Rail car unloading units	0.5 to 12	Transfer building #1	0.5 to 12	Transfer building #2	0.5 to 12	Transfer building #4	0.5 to 12	Crusher building #1	0.5 to 12	Unit one 13A	0.5 to 12	Unit one 13B	0.5 to 12	Unit two 14A	0.5 to 12	Unit two 14B	0.5 to 12	Limestone preparation building	0.5 to 12
Pollutant/Source PM ₁₀	Differential Pressure Range Across the Dust Collector (Inches of water gage)																						
(4) Rail car unloading units	0.5 to 12																						
Transfer building #1	0.5 to 12																						
Transfer building #2	0.5 to 12																						
Transfer building #4	0.5 to 12																						
Crusher building #1	0.5 to 12																						
Unit one 13A	0.5 to 12																						
Unit one 13B	0.5 to 12																						
Unit two 14A	0.5 to 12																						
Unit two 14B	0.5 to 12																						
Limestone preparation building	0.5 to 12																						

PERMIT HISTORY

This Approval Order shall supersede (if a modification) or will be based on the following documents:

Supersedes
Is Derived From

DAQE-AN103270029-22 dated June 22, 2022
Source Submitted NOI dated August 29, 2022

ACRONYMS

The following lists commonly used acronyms and associated translations as they apply to this document:

40 CFR	Title 40 of the Code of Federal Regulations
AO	Approval Order
BACT	Best Available Control Technology
CAA	Clean Air Act
CAAA	Clean Air Act Amendments
CDS	Classification Data System (used by Environmental Protection Agency to classify sources by size/type)
CEM	Continuous emissions monitor
CEMS	Continuous emissions monitoring system
CFR	Code of Federal Regulations
CMS	Continuous monitoring system
CO	Carbon monoxide
CO ₂	Carbon Dioxide
CO _{2e}	Carbon Dioxide Equivalent - Title 40 of the Code of Federal Regulations Part 98, Subpart A, Table A-1
COM	Continuous opacity monitor
DAQ/UDAQ	Division of Air Quality
DAQE	This is a document tracking code for internal Division of Air Quality use
EPA	Environmental Protection Agency
FDCP	Fugitive dust control plan
GHG	Greenhouse Gas(es) - Title 40 of the Code of Federal Regulations 52.21 (b)(49)(i)
GWP	Global Warming Potential - Title 40 of the Code of Federal Regulations Part 86.1818-12(a)
HAP or HAPs	Hazardous air pollutant(s)
ITA	Intent to Approve
LB/YR	Pounds per year
MACT	Maximum Achievable Control Technology
MMBTU	Million British Thermal Units
NAA	Nonattainment Area
NAAQS	National Ambient Air Quality Standards
NESHAP	National Emission Standards for Hazardous Air Pollutants
NOI	Notice of Intent
NO _x	Oxides of nitrogen
NSPS	New Source Performance Standard
NSR	New Source Review
PM ₁₀	Particulate matter less than 10 microns in size
PM _{2.5}	Particulate matter less than 2.5 microns in size
PSD	Prevention of Significant Deterioration
PTE	Potential to Emit
R307	Rules Series 307
R307-401	Rules Series 307 - Section 401
SO ₂	Sulfur dioxide
Title IV	Title IV of the Clean Air Act
Title V	Title V of the Clean Air Act
TPY	Tons per year
UAC	Utah Administrative Code
VOC	Volatile organic compounds