
RCRA Box 1475

Prepped by Candice Davis

Document Number:

1) II-I-57


Docket Number:

A-95-28

Docket No. A-95-28
Item No. II-I-57


May 1995

EPRI
Electric Power
Research Institute



EPRI/EPA 1995 Joint Symposium on Stationary Combustion NO_x Control

Book 1: Tuesday, May 16, 1995
Sessions 1, 2, 3



Sponsored by
Electric Power Research Institute
Generation Group
Air Quality Control Program

U.S. Environmental Protection Agency
Air and Energy Engineering Research Laboratory
Combustion Research Branch

May 16-19, 1995
Hyatt Regency Crown Center
Kansas City, Missouri

PERFORMANCE OF A CONTROLLED FLOW/ SPLIT FLAME LOW-NO_x BURNER SYSTEM ON A TANGENTIALLY FIRED BOILER

E. L. Morris, Jr., P.E.
Wisconsin Electric Power Company
231 W. Michigan St.
Milwaukee, Wisconsin 53201

T. W. Sweeney
Foster Wheeler Energy Corporation
Perryville Corporate Park
Clinton, New Jersey 08809-4000

Abstract

Topic presented is the performance of a controlled flow, split flame, low NO_x burner system installed on a tangentially-fired furnace, identifying specifically the results of both short term optimization testing and long term emission monitoring. This installation was the first time application of the controlled-flow, split-flame (CF/SF) low-NO_x burner design used on wall fired boilers, to a boiler having a tangential firing design. Installation of this low NO_x burner system to the furnace occurred without the modification of waterwalls, or addition of separated overfire air. Technical benefit achieved is reduction of fuel NO_x production on a per burner basis in a tangentially-fired boiler, with the burners operating at near stoichiometric conditions. Combination of optimized burners along with vertical secondary air staging was found to provide the desired emission reduction over the entire boiler load range. Ash LOI and unit efficiency values were found to remain consistent with pre conversion, baseline data values.

Introduction


A first time demonstration project involving retrofit low NO_x burners was undertaken beginning in 1992 on the 310 MW, Unit 7 boiler at Wisconsin Electric's Oak Creek Power Plant, which is located 20 miles south of Milwaukee on Lake Michigan. This demonstration project has been a joint effort between Foster Wheeler Energy Corporation (FWEC) and the Wisconsin Electric Power Company (WEPCo).

The Unit 7 boiler at Oak Creek Power Plant is designated as a Phase I unit under the 1990 Amendments to the Clean Air Act. The goal was to reduce NO_x emissions on this unit to less than 0.45 lb./MBtu by January 1, 1995, with minimal impact on LOI and unit efficiency. Baseline

TLN Burner Description

The windbox is partitioned with division plates. Flow is regulated for each partitioned burner lane by a secondary air damper and proportioned into three zones to create staging at the burner. The controlled flow is measured by flow elements installed in the primary and secondary air systems. The flow to the secondary air staging level and burners is shown schematically in Figure 1. The tip of the burner has a tilting split flame design. Arrangement of a single burner cell is shown in Figures 1 and 2.

Figure 1
TYPICAL SECONDARY AIR SYSTEM
FOR A TLN BURNER MODULE



BURNERS7

Figure 2
TYPICAL CORNER ARRANGEMENT OF TLN BURNER MODULE





Figure 3
TANGENTIALLY FIRED LOW NOx BURNER (TLN) MODULE ARRANGEMENT



Performance

Initial Comparison

Table II shows a comparison of the baseline operating data with the prototype TLNB system. This is provided for comparison of unit operating data to show that there was little or no change from the acceptable baseline, pre conversion test data, when operating on the midwestern bituminous coal fired during the testing of the prototype TLN burners.

TABLE II
BOILER PERFORMANCE COMPARATIVE DATA ON MIDWESTERN BITUMINOUS COAL
BASELINE VERSUS PROTOTYPE TLNB

<u>Parameter</u>	<u>Baseline</u>	<u>TLNB</u>
Load (MW)	300	300
FW Flow (KPPH)	1816	1824
SH Spray (KPPH)	53	42
RH Spray (KPPH)	40	46
Throttle Press. (psig)	2402	2404
MS Temp. (°F)	1061	1043
RH Temp. (°F)	1013	1003
NO _x (lb/10 ⁶ Btu)	0.68	0.38
Unburned Carbon(%)	9.19 @ 4.2% O ₂	8.0 @ 3.5% O ₂
CO (ppm)	20 - 40	20 - 40

Performance Following 1992 Coal Change

Coal was switched in the fall of 1992 from midwestern bituminous (1.6 percent sulfur, 6.8 percent ash, and HHV of 13,850 Btu/lb.) to a western bituminous coal (0.6 percent sulfur, 13 percent ash, and HHV of 13,000 Btu/lb.). This was to comply with a state fuel sulfur limit. Volatiles and fixed carbon for both coals were similar.

A change in performance was seen on all four furnaces at Oak Creek. On Oak Creek 8, the "sister" unit to Oak Creek Unit 7, which had not been modified to a low NO_x burner system, it was noted that the spray requirements were diminished. Inability to repeatedly obtain desired reheat and superheat temperatures on Unit 7 was observed. Ash deposits on the furnace walls were noted to be drier and less adherent to the walls. The sheets of dry ash were also noted to be "self shedding." A problem in the prototype burner tilts restricted effective temperature control.

Performance of Production TLN Burner System

Burner Tilts. Improvements in the coal nozzle tilt design permitted the production burners to achieve the design steam temperatures by means of controlled burner nozzle tilt.

Ash Deposits. The ash deposit pattern in the furnace was noted to have changed from the baseline, pre conversion pattern. The furnace walls were notably cleaner, and with the stable low NO_x burner ignition point being closer to the burners, there is a feeling that more heat is being

absorbed by the waterwalls. Flyash LOI was similar to values on the non-converted sister unit, Oak Creek Unit 8, and averaged in the range of 3 to 5 percent LOI.

Ash Characteristics. The original higher excess oxygen carried on the pre conversion furnace of 4.2% O₂ provided a much more radiant fire, and the ash on the walls from the midwestern coal was noted to glaze and become more adherent to the tubes than the drier western coal ash.

Steam Temperatures. Selective soot blowing of the rear convective superheat elements, along with the furnace exit aperture reheat bundles, was found to enable design steam temperatures of 1050 °F/1000 °F (superheat/reheat) to be maintained at full load. Temperatures are not a problem at low load. Soot blowing in the furnace was found to reduce steam temperatures.

Exit Oxygen and Furnace Temperature Profiles. The furnace exit oxygen and steam temperature profiles across the furnace are more even following the balancing of air flows to each burner. Evidence of a more uniform gas flow was confirmed by the lack of a higher ash wear area that had typically been observed during outages on the pre-conversion furnace.

Flame Stability. Balancing of air flows to each burner also resulted in more stable flames at low load and eliminated what is referred to as "cold corners", which were burners on the pre-conversion unit that had an ignition point farther from the corner.

Emission Test Results

Short Term, Single Point Test Results

Table III shows the best repeatable results obtained for the short term, single load point optimization testing. Single point tests were each two hours in length with the a test variable controlled. A test matrix was followed to determine the effects of altering the test variable. All end of day tests were repeated on the following day of testing to ascertain that conditions could be repeated. A total of 152 tests were conducted on 70 non-consecutive test dates to define the response of the new burner system to variations in adjustable parameters.

TABLE III
OAK CREEK UNIT 7 TLN BURNER DEMONSTRATION RESULTS SUMMARY
NO_x (lb/MBtu) EMISSIONS VERSUS LOAD (MW) COMPARISON


Test Phase (Dates)	NO _x Emissions lb/MBtu		
	Low Load (125 MW)	Medium Load (230-260 MW)	Full Load (260-300 MW)
Baseline (pre conversion) (12/91 - 1/92)	0.67	0.61	0.68
Production TLNB - (3/94 - 12/94)	0.31	0.28	0.35

Long Term Emission Test Results

Table IV displays the unit CEM hourly averages at each 10 megawatt load point along the daily load curve of Oak Creek Unit 7 for the period of January 1, 1995 to March 15, 1995. The data for this 74 day period was obtained from certified stack CEM data. For comparison, the rolling hourly average for the unit during the first two months of 1995 was 0.364 lbs.NOx/mmBtu.

Table IV

**WEPCO
Oak Creek Unit 7
Jan - Mar 1995
NOx vs Load
hourly data averaged over 10 MW intervals**



Conclusion

The goals of the demonstration project have been achieved. A production burner system was developed and unit performance has been acceptable while achieving low NO_x emissions. Final tuning of boiler controls is in progress. Conversion of the similar Oak Creek Unit 8 tangentially fired furnace to an identical low NO_x burner system has been accomplished and that unit is going into service in mid - April 1995.

References

1. Eskinazi, D., 1993, "Commercially Available Retrofit Combustion NO_x Controls", "Retrofit NO_x Controls For Coal-Fired Utility Boilers," Vol. TR-102071, Electric Power Research Institute, Palo Alto, Calif. , pp. 5-1 to 5-51.
2. Morris, E. L., and Sweeney, T. W., "Development Of A Tangentially Fired, Controlled Flow, Split Flame Low-NO_x Burner System On A Coal Fired Utility Boiler," Presented at *Electric Power Research Institute, "Workshop On NO_x Controls for Utility Boilers"*, Scottsdale, AZ , May 1994.
3. Morris, E. L., and Sweeney, T. W., "Application Of Controlled Flow, Split Flame Low-NO_x Burners On A Tangentially Fired Boiler," Presented at the ASME Joint International Power Generation Conference in Phoenix, AZ , October 1994.
4. Vatsky, J. , 1993, "Attaining The Clean Air Act NO_x Requirements On Wall-Fired & Tangentially-Fired Steam Generators," Presented to representatives of EPA, and DOE, Oak Creek, WI., January 21, 1993.